



Upgrade Elec Sys, CU Den Bldg.

Project Number – 21-174017

Friday, January 26, 2024

ADDENDUM 1

QUESTIONS/RESPONSES:

Addendum for Clarification

Because the current lead time for switch gear may be 60 weeks or more, that portion of the project is expected to progress until the end of the summer of 2025. The University would like to pursue any potential work not involving long lead procurement to begin during the 2024 summer to minimize the amount of work needed in 2025.

Once a contractor is selected, the University's expectation is that long lead items will be identified and locked in as soon as possible after submittals/approvals, etc. and a schedule is generated to identify what work will occur in the 2024 summer versus the 2025 summer.

Please submit any questions in writing by 2pm on February 6, 2024.

Please review the following schedule

- | | |
|--|------------------|
| 1. Advertisement | 1/16/24 |
| 2. Pre bid walk | 1/23/24 @ 10am |
| 3. Questions Due | 2/6/24 @ 2pm |
| 4. Questions answered | 2/13/24 @2pm |
| 5. Bids and Qualifications received/public opening | 2/27/24 @ 2pm |
| 6. Contract negotiations with apparent low bidder | To be determined |
| 7. Contract executed | To be determined |
| 8. Contract complete | To be determined |

END OF ADDENDUM 1