

SECTION 10 44 00 - FIRE PROTECTION SPECIALTIES

PART 1 - GENERAL

1.1 QUALITY ASSURANCE

- A. Fire Extinguishers: Provide in accordance with NFPA 10.

PART 2 - PRODUCTS

2.1 PORTABLE, HAND-CARRIED FIRE EXTINGUISHERS:

- A. Multipurpose dry-chemical type, manufacturer's standard container: 4-A:60-B:C, 10-lb.
- B. Other types: Not permitted, except if approved by the University Fire and Life Safety Officer, through the University Project Manager.

2.2 FIRE PROTECTION CABINET:

- A. Type and Size: For indicated fire extinguisher.
- B. Door Type: Solid with vertical window.
- C. Door Glazing: Acrylic sheet, glass not permitted.
- D. Accessories: Door locks not permitted unless approved by the University Fire and Life Safety Officer, through the University Project Manager.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Mounting:
 - 1. Locations: As approved by the University Fire and Life Safety Officer through the University Project Manager.
 - 2. Mounting Height: 48" to center of door handle from finished floor.
 - 3. Accessibility: Comply with accessibility requirements for both approach and reach.

END OF SECTION 10 44 00