

## FIRE ALARM STATISTICS FOR CU DENVER CAMPUS 2021

Facility	Street Address	Total Alarms/ Building	Fire Number	Cause of Alarm	Number of Injuries Requiring Medical Treatment	Number of Deaths Related to Fire	Value of Property Damage Caused by Fire/Smoke
Academic Building One/ABI	1201 Larimer St.	0	0				
City Heights	1191 Larimer St.	1	0	1). Burnt Popcorn	0	0	0
CU Denver Bldg./CU	1250 14th St.	0	0				
CU Denver Business School	1475 Lawrence St.	0	0				
Lawrence Street Center/LW	1380 Lawrence St.	1	0	1).Smoke (false).	0	0	0
Lola & Rob Salazar Student Wellness	1355 12th St.	0	0				
Lynx Crossing	318 Walnut St.	0	0				
<b>Total CU Denver 2020</b>		<b>2</b>	<b>0</b>		<b>0</b>	<b>0</b>	<b>0</b>

## FIRE ALARM STATISTICS FOR CU ANSCHUTZ MEDICAL CAMPUS 2021

Facility	Street Address	Total Alarms/ Building	Fire Number	Cause of Alarm	Number of Injuries Requiring Medical Treatment	Number of Deaths Related to Fire	Value of Property Damage Caused by Fire/Smoke
AD1/L15	12631 E. 17th Ave.	1	0	1). Accidental Pull	0	0	0
BDC/M20	1775 Aurora Ct.	1	0	1). False Alarm-Smoke (dust).	0	0	0
Bldg. 400/Q09	2469 E. 17th Pl.	0	0				
Bldg. 401/R09	1784 Racine St.	0	0				
Bldg. 402/S09	12474 E. 19th Ave.	1	0	1). Fireworks (False).	0	0	0
Bldg. 406/T09	12477 E. 19th Ave.	0	0				
Bldg. 407/U09	12454 E. 19th Pl.	0	0				
Fitzsimons Bldg./Q20	13001 E. 17th Pl.	0	0				
Bldg. 532/S21	12856 E. 19th Ave.	0	0				
Bldg. 533/R24	13001 E. 17th Pl.	0	0				
Bldg. 534/S25	13001 E. 17th Pl.	0	0				
Bldg. 610/Q34	13309 E. 17th Pl.	0	0				
Campus Services/T36	1945 N. Wheeling St.	0	0				
Central Utilities Plant/S34	13350 E. 19th Ave.	0	0				
Education One/P26	13070 E. 19th Ave.	1	0	1). Frozen Sprinkler Heads	0	0	0
Education Two-North/P28	13120 E. 19th Ave.	1	0	1). Smoke Det (false).	0	0	0
Education Two-South/L28	13121 E. 19th Ave.	0	0				
EHGS/R30-R31	13178 E. 19th Ave.	0	0				

Fire Station/X28	1997 Uvalda Ct.	0	0				
Fulginiti Center/R27	13080 E. 9th Ave.	0	0				
Health and Wellness Center/V08	12348 E. Montview Blvd.	1	0	3). Smoke (false).	0	0	0
Health Sciences Library/V23	2950 E. Montview Blvd.	3	0	1). BSMNT Smoke/Steam.2). Smoke (false) 3). Smoke (false).	0	0	0
Henderson Parking Structure/VI7	12706 E. Montview Blvd.	0	0				
Leprino Garage	12401 E. 17th Ave	1	0	1). Fire Pull (False)	0	0	0
Nighthorse Campbell/M24	13055 E. 17th Ave.	0	0				
PASCAL/P30	13188 E. 19th Ave.	0	0				
Perinatal Research Facility/AK32	13243 E. 23rd Ave.	0	0				
School of Pharmacy/V20	12850 E. Montview Blvd.	0	0				
Research One-North/P18	12800 E. 19th Ave.	0	0				
Research One-South/L18	12801 E. 17th Ave.	0	0				
Research Two/P15	12700 E. 19th Ave.	5	0	1). Dryer setting on detector. 2). Broken Sprinkler Head. 3). Leaking Head 4). Smoke (hot plate left on). 5). Sight of smoke (False).	0	0	0
School of Dental Med./L26	13065 E. 17th Ave.	0	0				
<b>Total CU Anschutz 2020</b>		<b>15</b>	<b>0</b>		<b>0</b>	<b>0</b>	<b>0</b>